

MINIMUM 12' CLEARANCE

MAST NO LESS THAN 2', NO MORE THAN 3'

BARE COPPER GROUND RUNS THROUGH MAST AND METER BASE OR GROUNDED INSIDE METER BASE FROM GROUND ROD AND CLAMP

MOUNT METER BASE EYE LEVEL

7' GALVANIZED OR COPPER GROUND ROD AND CLAMP

MINIMUM 12' CLEARANCE

BARE COPPER GROUND TO WEATHERHEAD WITH 18" TAIL OR GROUNDED INSIDE METER BASE FROM GROUND ROD AND CLAMP

Clarke-Washington EMC	
TYPICAL HOUSE CONNECTION	
Drawing #	
Date:	
Designed By:	Sheet ___ Of ___